

Fig 256B

TYPE DB PIPE INTERRUPTER

NABIC pipe interrupters DB type are WRAS approved safety fittings in accordance with EN 1717 up to fluid category 4.

- Clean and flush pipework thoroughly before fitting the device.
- NABIC pipe interrupters are to be installed in accordance with EN 1717.
- It is recommended that a fine strainer be fitted before the pipe interrupter to ensure satisfactory operation during service.
- When fitting the pipe interrupter it is important that the correct direction of flow is observed. See arrow on body.
- Pipe interrupters must be fitted in the vertical position.
- The maximum permissible working pressure is 6 bar; the maximum permissible temperature is 65°C.
- The connecting pipe on the discharge side should be sized at least the same diameter as the input side.
- The pipe interrupter is only to be fitted on open-end installations, i.e. there must be no valve or shut off device fitted after the unit.
- They must be installed at least 150 mm above any subsequent maximum possible non-potable water level.
- When fitting it must be ensured that the unit can be removed at any time for replacements of the inserts.
- Precautions should be made to ensure that any water discharged during service does not cause damage to surrounding property.
- The pipe interrupter design permits good through flow of water, if there is a strong flow restriction after the interrupter or if a relatively long outlet pipe is fitted, water may be discharged.
- It is advisable to check the interrupter for possible water discharge immediately following installation.
- It is recommended that an inspection of the pipe interrupter be carried out annually as a visual check by the operator or by the installation company.
- The hose membrane should be replaced at regular intervals; recommended maximum length of service time is three years. Complete replacement inserts are available.



NABIC Fig 256B Type DB Pipe Interrupter

NABIC™

46-48 WILBURY WAY, HITCHIN, HERTFORDSHIRE, SG4 0UD
 Tel: +44 (0) 1462 443 278 Fax: +44 (0) 1462 443 127
 E-mail: nabicsales@cranebsu.com Web: www.nabicvalves.com

Every effort has been made to ensure that the information contained in this publication is accurate at the time of publishing. NABIC assumes no responsibility or liability for typographical errors or omissions or for any misinterpretation of the information within the publication and reserves the right to change without notice.

N_FIG256B_1215
 IOM_0123_1/2